



NOTE:
 FIXINGS AND GASKET
 TO SUIT JOINT FLANGE
 ARE SUPPLIED INSIDE
 THE TANK.

DRAWINGS NO.		PW225-2		TITLE		PW225/2 TWO PIECE COLD WATER STORAGE TANK	
ALL DIMENSIONS ± 1mm UNLESS OTHERWISE STATED		SCALE 1:12		DATE		18/11/2008	
DRAWN BY N. DUDDY		CUSTOMER CUSTOMER		DATE		18/11/2008	
NOTES		All Purewater tanks must be fully supported on a flat, level & continuous foundation providing structural support to the tank when full to maximum operating capacity. Under no circumstances should the tank body be used to provide support to pipework and ancillary items. The tank lid is a structural part of the tank and must be in place and sealed correctly when water is contained within the tank.		DATE		18/11/2008	
DATE		MOD		NOTES		TANK SPECIFICATION:	
DATE		A		FIRST ISSUE		INTERNAL DIMS 610 x 610 x 610mm	
						EXTERNAL DIMS 760 x 760 x 650mm	
						FLANGE SECTION DIMS 760 x 760 x 315mm	
						NOM. CAPACITY 225 Litres	
						DRY WEIGHT 175kg	
						INSULATION 25mm	
<p>purewater storage ltd</p> <p>Trukey Caples Farm Middleton Timeworth Salford B78 2BU</p> <p>Tel: 0121 323 4000 Fax: 0121 323 4400 www.purewaterstorage.co.uk</p>							